

Phone: 503-554-8333 1-855-554-8333 (TF) Mail: P.O. Box 699 Newberg, OR 97132 info@hilandwater.com www.hilandwater.com

Email:

Internet:

Otter Rock Water District Monthly Operations Report: August 2023

Diamond Maps Link - https://diamondMaps.com/map.ashx?key=8054230906203407120

Spring flow – Aug 1, 2023

September 6, 2023

Source	Flow rate
Spring 1 flow rate	26 gpm
Spring 2 flow rate	31 gpm
Spring 3 flow rate	31 gpm
Reservoir overflow rate	29 gpm

Sep. preview: Spring flow – Se	eptember 1, 2023

Source	Flow rate
Spring 1 flow rate	23 gpm
Spring 2 flow rate	17 gpm
Spring 3 flow rate	31 gpm
Reservoir overflow rate	7 gpm

Chlorine levels

	First User	Distribution System
Average	0.2 ppm	0.22 ppm
High	0.29 ppm	0.41 ppm
Low	0.24 ppm	0.28 ppm

Other notable activities during the month:

8/8 - Locate at 6760 Gladys Ave

8/21 - Turned on water for Lot 6 on Mahala.

8/29-8/30 - Responding to 6885 Otter Crest Loop customer who couldn't get their water off. Originally thought the corp stop didn't work, but later discovered that there is a second corp stop on the property that feeds the neighbor across Otter Crest. Found the correct corp stop and got the water off.