



Phone: 503-554-8333  
1-855-554-8333 (TF)  
Mail: P.O. Box 699  
Newberg, OR 97132  
Email: [info@hilandwater.com](mailto:info@hilandwater.com)  
Internet: [www.hilandwater.com](http://www.hilandwater.com)

January 13, 2023

## Otter Rock Water District Monthly Operations Report: December 2022

Spring flow – December 1, 2022

Source	Flow rate
Spring 1 flow rate	26.5 gpm
Spring 2 flow rate	18 gpm
Spring 3 flow rate	30 gpm
Reservoir overflow rate	27.3 gpm

January preview: Spring flow – January 2, 2023

Source	Flow rate
Spring 1 flow rate	69 gpm
Spring 2 flow rate	300 gpm
Spring 3 flow rate	36 gpm
Reservoir overflow rate	113 gpm

Chlorine levels

	First User	Distribution System
Average	0.23 ppm	0.28 ppm
High	0.30 ppm	0.36 ppm
Low	0.18 ppm	0.20 ppm

Other notable activities during the month:

Water service at 6225 C Ave. was turned off and then re-established for the homeowner on 12/12/22.

Aaron Olson reached out to the county road department about the washout conditions on 12/14/22.

Field techs continued to work on building a vault for the flow meter until the project was stopped.

Cody met with Craig to exercise normally closed valves and establish best practices to operate the system in case of an emergency on 12/23/22.