



Phone: 503-554-8333  
1-855-554-8333 (TF)  
Mail: P.O. Box 699  
Newberg, OR 97132  
Email: [info@hilandwater.com](mailto:info@hilandwater.com)  
Internet: [www.hilandwater.com](http://www.hilandwater.com)

March 10, 2023

## Otter Rock Water District Monthly Operations Report: February 2023

Spring flow – February 1, 2023

Source	Flow rate
Spring 1 flow rate	82 gpm
Spring 2 flow rate	300 gpm
Spring 3 flow rate	33 gpm
Reservoir overflow rate	113 gpm

March preview: Spring flow – March 1, 2023

Source	Flow rate
Spring 1 flow rate	45 gpm
Spring 2 flow rate	90 gpm
Spring 3 flow rate	32 gpm
Reservoir overflow rate	100 gpm

Chlorine levels

	First User	Distribution System
Average	0.25 ppm	0.21 ppm
High	0.31 ppm	0.26 ppm
Low	0.21 ppm	0.17 ppm

Other notable activities during the month:

A leak was identified at the beginning of the month and repaired on February 3 (6865 Gladys Ave)

While on site February 3, Curtis and Tiger replaced three defective meters at the following locations:

330 1<sup>st</sup> St.  
6750 Ellie Ave  
6815 Gladys

Construction of the brick vault was completed on February 15.

Cody Scott repaired a leak on February 17 (6865 Boland Way).

Cody Scott shut off water at 755 3<sup>rd</sup> St. on February 24.