



Phone: 503-554-8333  
1-855-554-8333 (TF)  
Mail: P.O. Box 699  
Newberg, OR 97132  
Email: [info@hilandwater.com](mailto:info@hilandwater.com)  
Internet: [www.hilandwater.com](http://www.hilandwater.com)

September 9, 2022

## Otter Rock Water District Monthly Operations Report: August 2022

Spring flow – August 1, 2022

Source	Flow rate
Spring 1 flow rate	41 gpm
Spring 2 flow rate	69 gpm
Spring 3 flow rate	38 gpm
Reservoir overflow rate	82 gpm

Chlorine levels

	First User	Distribution System
Average	0.20 ppm	0.24 ppm
High	0.34 ppm	0.51 ppm
Low	0.13 ppm	0.12 ppm

Other notable activities during the month:

Cody Scott gathered SOC samples. Results are due to OHA by the end of 2022 and generally take around six weeks for the lab to process. In 2022, there has been a shortage of SOC kits available due to an unusually high number of water systems being required to gather SOC samples by the end of the year.

The following water meters were installed for previously unmetered properties:

Date	Address	Meter Serial #
August 10, 2022	6875 Ellie	89211679
August 10, 2022	6895 Ellie	89211680
August 10, 2022	6760 Gladys	89458689

Work was performed at additional properties to prepare for meter installations in September.